

Water Service Line Photo Inspection Checklist

Required information

Please email photos to drinkingwaterplanreview.mdh@state.mn.us and include the following information in the subject line: **“Photo Inspection”/Project Name/MDH Plan Number** (found on the plan approval letter).

Required photo documentation

Please include photos showing the following:

- Service line connection to wellhead
- All service line joints and fittings
- Service line material and size, including closeup of all pipe markings
- Watertight entry of pipe into building
- Thrust blocking (as applicable)
- Any yard hydrants, with identifying markings
- Trenches and/or entry/exit pits
 - Completion of excavation
 - Bedding with pipe on top
 - Layers of bedding on top of pipe.
 - Site-identifying objects/structures in photos
- Required well sampling faucet
- Any interior plumbing, including pressure tank(s) and shutoff valve with product identification visible

Pressure Testing

Water service lines must be tested upon completion. See [Water Service Line Pressure Testing \(PDF\)](https://www.health.state.mn.us/communities/environment/water/docs/planreview/wslpressuretest.pdf) (<https://www.health.state.mn.us/communities/environment/water/docs/planreview/wslpressuretest.pdf>).

Minnesota Department of Health
Drinking Water Protection Section
PO Box 64975
St. Paul, MN 55164-0975
651-201-4700
drinkingwaterplanreview.mdh@state.mn.us

January 2026

To obtain this information in a different format, call: 651-201-4700.